

**PRODUCT FICHE**Information requirements for boiler space heaters, boiler combination heaters and cogeneration space heaters  
(COMMISSION DELEGATED REGULATIONS No. 811-814/2013)

Model(s):	<b>C38GC45v1, CONDENS 100 CH2 45</b>		
Condensing boiler [yes/no]:	yes		
Low-temperature (**) boiler [yes/no]:	yes		
B1 boiler [yes/no]:	no		
Cogeneration space heater [yes/no]:	no	If yes, equipped with a supplementary heater: [yes/no]: no	
Combination heater [yes/no]:	no		

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
<b>Rated heat output</b>	$P_{rated}$	45	kW	<b>Seasonal space heating energy efficiency</b>	$\eta_s$	91	%
For boiler space heaters and boiler combination heaters: Useful heat output				For boiler space heaters and boiler combination heaters: Useful efficiency			
At rated heat output and high-temperature regime (*)	$P_4$	45,0	kW	At rated heat output and high-temperature regime (*)	$\eta_4$	87	%
At 30 % of rated heat output and low-temperature regime (**)	$P_1$	5	kW	At 30 % of rated heat output and low-temperature regime (**)	$\eta_1$	94	%
<b>Auxiliary electricity consumption</b>				<b>Other items</b>			
At full load	$e_{lmax}$	0,180	kW	Standby heat loss	$P_{stby}$	0,4	kW
At part load	$e_{lmin}$	0,076	kW	Ignition burner power consumption	$P_{ign}$	0,0	kW
In standby mode	$P_{SB}$	0,004	kW	Emissions of nitrogen oxides	$NO_x$	18	mg/kWh
				Noise level	$L_{WA}$	48	dB

For combination heaters:

Contact details: [office.vaduri@kober.ro](mailto:office.vaduri@kober.ro)  
[www.motan.ro](http://www.motan.ro)  
Telephone: 0233 241746  
Fax: 0233 241929

Name and address of the manufacturer: KOBER Ltd VADURI Branch, Piatra Neamt town, Neamt District, Romania

(\*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(\*\*) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Seasonal space heating energy efficiency class:

**A**