

PRODUCT FICHEInformation requirements for boiler space heaters, boiler combination heaters and cogeneration space heaters
(COMMISSION DELEGATED REGULATIONS No. 811-814/2013)

Model(s):	C38GC70v1, CONDENS 100 CH2 70		
Condensing boiler [yes/no]:	yes		
Low-temperature (**) boiler [yes/no]:	yes		
B1 boiler [yes/no]:	no		
Cogeneration space heater [yes/no]:	no	If yes, equipped with a supplementary heater: [yes/no]: no	
Combination heater [yes/no]:	no		

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output	P_{rated}	68	kW	Seasonal space heating energy efficiency	η_s	91	%
For boiler space heaters and boiler combination heaters: Useful heat output				For boiler space heaters and boiler combination heaters: Useful efficiency			
At rated heat output and high-temperature regime (*)	P_4	68,0	kW	At rated heat output and high-temperature regime (*)	η_4	87	%
At 30 % of rated heat output and low-temperature regime (**)	P_1	10	kW	At 30 % of rated heat output and low-temperature regime (**)	η_1	94	%
Auxiliary electricity consumption				Other items			
At full load	e_{lmax}	0,370	kW	Standby heat loss	P_{stby}	0,4	kW
At part load	e_{lmin}	0,110	kW	Ignition burner power consumption	P_{ign}	0,0	kW
In standby mode	P_{SB}	0,004	kW	Emissions of nitrogen oxides	NO_x	8	mg/kWh
				Noise level	L_{WA}	48	dB

For combination heaters:

Contact details: office.vaduri@kober.ro
www.motan.ro
Telephone: 0233 241746
Fax: 0233 241929

Name and address of the manufacturer: KOBER Ltd VADURI Branch, Piatra Neamt town, Neamt District, Romania

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Seasonal space heating energy efficiency class:

A